



LINEAR GAP SEALS SCHEME SDP 14

Certificate number: IFCC 1924

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

MDL Insulations Ltd

Villa Works, Plant Lane Business Park
Plant Lane, Burntwood
Staffordshire
WS7 3GN
Tel: 01543 450311

Who manufacture the following systems:

MULTI APP SLAB Series 7280, Series 5800, & Series 1000 Cavity Barriers.

At manufacturing site: Unit 5 Swaffield Park, Cannock, WS11 7FU

have satisfied the requirements of the Linear Gap Scheme SDP 14 v1.4. This includes the testing of products to **BS EN 1366-4: 2021**, the inspection of their Factory Production Control, and continuing surveillance audits, and testing of samples of products taken from production. The product specification and reports to achieve **up to 120 minutes integrity and insulation** are detailed on page 2 of this certificate.

Assessment Report: PAR/24205/01. Test reports: WF516733/R, WF516732/R, WF517034/R

Initial Certification: 02 May 2024


Valid to: 01 May 2029

Revised: 22 October 2024

Issue number: 2

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 3 pages.
Publication of this certificate is permitted.*



The production of fire-resistant products are manufactured in accordance with assessment PAR/24205/01 and test reports referenced within the following tables:

Horizontal

Product / Test Reports	Product thickness (mm)	Product length (mm)	Fit type	Integrity (mins)	Insulation (mins)	Gap width (mm)	Fixing Type	Qty fixings	Fixing centres (mm)
WF516733/R Specimen A	75	1200 800 600	5mm compression	132	132	286	Galvanised steel hanger	6	1000 600 400
WF516733/R Specimen G	100	1200 800 600	5mm compression	132	129	350	Galvanised steel hanger	6	1000 600 400
WF516733/R Specimen H	75	1200 800 600	5mm compression	132	132	350	Galvanised steel hanger	6	1000 600 400
WF516733/R Specimen I	50	1200 800 600	5mm compression	132	23	250	Galvanised steel hanger	6	1000 600 400


Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.



The production of fire-resistant products are manufactured in accordance with assessment PAR/24205/01 and test reports referenced within the following tables:

Vertical

Product / Test Reports	Product thickness (mm)	Product length (mm)	Fit type	Integrity (mins)	Insulation (mins)	Gap width (mm)	Fixing Type	Qty fixings	Fixing centres (mm)
WF516732/R Specimen A	50	1200 900 500	5mm compression	132	31	255	Galvanised steel hanger	8	500 350 300
WF516732/R Specimen B	100	1200 900 500	5mm compression	64	64	450	Galvanised steel hanger	8	500 350 300
WF516732/R Specimen C	75	1200 900 500	5mm compression	132	53	450	Galvanised steel hanger	8	500 350 300
WF516732/R Specimen D	75	1200 900 500	5mm compression	132	132	450	Galvanised steel hanger	8	500 350 300
WF517034/R Specimen A	75	1200 900 500	5mm compression	132	84	350	Galvanised steel hanger	8	500 350 300
WF517034/R Specimen B	75	1200 900 500	5mm compression	132	59	347	Galvanised steel hanger	8	500 350 300
WF517034/R Specimen F	100	1200 900 500	5mm compression	132	119	350	Galvanised steel hanger	8	500 350 300

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.