



LINEAR GAP SEALS SCHEME SDP 14

Certificate number: IFCC 1926

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

MDL Insulations Ltd

Villa Works, Plant Lane Business Park
Plant Lane, Burntwood
Staffordshire
WS7 3GN
Tel: 01543 450311

Who manufacture the following systems:

**Series 2024 Multi Sock, Series 2000 SP Multi Sock,
Series 2500 Party Wall DPC, Series 2500+ Party Wall DPC Plus,
Series 2600 Firezero Closer, Series 3100 Edge Seal Sock,
Series 3300 Party Wall Cavity Barrier, Series 3300+ Party Wall Cavity
Barrier Plus**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS EN 1366-4**, the inspection of their Factory Production Control, and continuing surveillance audits, and testing of samples of products taken from production. The product specification and reports to achieve **up to 120 minutes integrity and insulation** are detailed below and on page 2 of this certificate.

Test reports: WF516733/R, WF516732/R, WF517034/R

Initial Certification: 02 May 2024

Valid to: 01 May 2029

Issue number: One

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 3 pages.
Publication of this certificate is permitted.*



The production of fire-resistant products are manufactured in accordance with assessment PAR/24205/02 and test reports referenced within the following tables:

Horizontal

Product / Test Reports	Product thickness (mm)	Product length (mm)	Fit type	Integrity (mins)	Insulation (mins)	Gap width (mm)
WF516733/R Specimen B	150	1200 800 600	30mm compression	51	51	300
WF516733/R Specimen C	120	1200 800 600	20mm compression	64	64	200
WF516733/R Specimen D	100	1200 800 600	20mm compression	77	77	140
WF516733/R Specimen E	75	1200 800 600	10mm compression	132	68	65
WF516733/R Specimen F	65	1200 800 600	15mm compression	132	132	50

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.



The production of fire-resistant products are manufactured in accordance with assessment PAR/24205/02 and test reports referenced within the following tables:

Vertical

Product / Test Reports	Product thickness (mm)	Product length (mm)	Fit type	Integrity (mins)	Insulation (mins)	Gap width (mm)
WF516732/R Specimen E	65	1200 800 600	15mm compression	132	61	50
WF516732/R Specimen F	75	1200 800 600	10mm compression	132	132	65
WF517034/R Specimen C	100	1200 800 600	10mm compression	116	64	140
WF517034/R Specimen D	120	1200 800 600	20mm compression	117	70	200
WF517034/R Specimen E	150	1200 800 600	30mm compression	36	31	300

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.